AquaLab Water Analysis P.O. Box 356 Twain Harte CA 95383	State Certification # 1359 (209) 586-3400 Fax: (209) 586-1492

BACTERIOLOGICAL EXAMINATION OF WATER

YOSEMITE ALPINE CSD P O BOX 31 FISH CAMP CA 93623	SWRCB 2210923 YACSD@HOTMAIL.COM mcgintyt@pacbell.net

KAREN C) 559 301 8719 / 642 2893 DICK RYON 925 447 8907 TIM 415 850 8755	Date: 1·12·21	Sampler: LEP

Source		Reason	Type
1) Surface/ Spring 2) Well Head 3) Well Distribution	4) Reservoir 5) Distribution 6) Treatment Plant	A) Routine B) Repeat C) Special	C) Total Coliform F) Fecal Coliform H) Heterotrophic Plate Count E) *E. coli*

5391-0 Collection Data | Five Portions sm 9221 | Presence/Absence sm 9223B

Lab ID / Bottle ID	Time	Location	CL2	Source	Reason	Type	Vol mL	# Positive Tubes Prsmp 24	Prsmp 48	Confirmed 24	Confirmed 24	Confirmed 48	Confirmed 48	#	Coliform P/A or MPN Total	Fecal	E.coli	CFU mL 35 C @ 48HR
0 / 4+A	0854	OT @ 1193 SILVERTIP	1.05	3	A	C	20.0	0	0					0	<1.1			

Notification/Comments/Transported @ < 10 degree C

Set-Up: Date/Time/By: 1·12 1500 LLJ

Completed: Date/By: 1·14·2021 LEP

These Tests (✓) Do Meet State Standards
( ) Do Not