



**PRECISION ENVIRO-TECH**

**Analytical Laboratory**

3935 N. Coronado Ave, Stockton CA. 95204 Phone: (209) 477-8105

16 July 2025

Tim McGinty

Yosemite Alpine CSD

P.O.Box 31

Fish Camp, CA 93623

RE: CA2210923-Distribution

Enclosed are the results for sample(s) received on 08-Jul-25 12:20 by Precision Enviro-Tech. The sample(s) were subcontract to another laboratory for analyzed according to instructions in accompanying chain-of-custody.

Thank you for the opportunity to service the needs of your company.

Sincerely,

Technical Manager





**CALIFORNIA LABORATORY SERVICES**

*Committed. Responsive. Flexible.*

July 16, 2025

**CLS Work Order #: 25G0499**

**COC #:**

Jonathan HV Lee  
Precision Enviro-Tech  
3935 N. Coronado Ave  
Stockton, CA 95204

**Project Name: 2507102**

Enclosed are the results of analyses for samples received by the laboratory on 07/08/25 17:51. Samples were analyzed pursuant to client request utilizing EPA or other ELAP approved methodologies. I certify that the results are in compliance both technically and for completeness.

Analytical results are attached to this letter. Please call if we can provide additional assistance.

Sincerely,

Daniel Johnson  
Technical Director

CA SWRCB ELAP Accreditation/Registration number 1233

**PRECISION ENVIRO-TECH**  
Analytical Laboratory

3935 N. Coronado Ave, Stockton CA. 95204 Phone: (209) 477-8105

2560499

**SUBCONTRACT  
ORDER**

**Sending Laboratory:**

Precision Enviro-Tech  
3935 N. Coronado Ave  
Stockton, CA 95204  
Phone: (209) 477-8105  
Fax: (209) 477-8135  
  
Project Manager: Jonathan H.V. Le

**Subcontracted Laboratory:**

CALIFORNIA LABORATORY SERVICES  
3249 Fitzgerald Road  
Rancho Cordova, CA 95742  
Phone: (916) 638-7301  
Fax: (916) 638-7301

**Work Order: 2507102**

**Sample ID: 2507102-01** -Outside Tap @ Forest **Water Sampled: 07/08/2025 09:31 Sampler: Miguel Cueto**

Analysis	Sample Name	Project Name
Total Escherichia Coli-SM9223B-QT24	Outside Tap @ Forest	CA2210923
Total Coliform-SM9223B-QT24	Outside Tap @ Forest	CA2210923
Residual Chlorine (Field Measurement) = $\emptyset$	Outside Tap @ Forest	CA2210923

Containers Supplied:

please email Report: jhvle@petallab.net (process payment with credit card on file)

  
Released By

07/08/25 1751  
Date

  
Received By

07/08/25-1751  
Date

5.6/6.2




# CALIFORNIA LABORATORY SERVICES

*Committed. Responsive. Flexible.*

Precision Enviro-Tech 3935 N. Coronado Ave Stockton, CA 95204	Project: 2507102 Project Number: [none] Project Manager: Jonathan HV Lee	CLS Work Order #: 25G0499 COC #:
---	--	-------------------------------------

## Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
<b>2507102-01 -Outside Tap @ Forest (25G0499-01) Water Sampled: 07/08/25 09:31 Received: 07/08/25 17:51</b>									
E. Coli	<1	1.0	MPN/100 mL	1	2505711	07/08/25	07/09/25	SM9223	
Residual Chlorine	0	0.10	mg/L	"	"	07/08/25	07/08/25	SM 4500-CL-G	FT-C
Total Coliforms	<1	1.0	MPN/100 mL	"	"	07/08/25	07/09/25	SM9223	



# CALIFORNIA LABORATORY SERVICES

*Committed. Responsive. Flexible.*

Page 3 of 3

07/16/25 15:43

Precision Enviro-Tech  
3935 N. Coronado Ave  
Stockton, CA 95204

Project: 2507102  
Project Number: [none]  
Project Manager: Jonathan HV Lee

**CLS Work Order #: 25G0499**  
COC #:

## Notes and Definitions

FT-C The analysis was performed in field by client.  
BT-4 <1  
A-RES 0  
DET Analyte DETECTED  
ND Analyte NOT DETECTED at or above the reporting limit (or method detection limit when specified)  
NR Not Reported  
dry Sample results reported on a dry weight basis  
RPD Relative Percent Difference