



**PRECISION ENVIRO-TECH**

**Analytical Laboratory**

3935 N. Coronado Ave, Stockton CA. 95204 Phone: (209) 477-8105

15 January 2025

Tim McGinty

Yosemite Alpine CSD

P.O.Box 31

Fish Camp, CA 93623

RE: CA2210923-Distribution

Enclosed are the results for sample(s) received on 14-Jan-25 16:20 by Precision Enviro-Tech. The sample(s) were analyzed according to instructions in accompanying chain-of-custody, utilizing EPA or other ELAP approved methodologies and . Results are summarized on the following pages.

Note: Total Coliform and E.Coli Test in Drinking Water using Coli-ert (P/A) or by Quanti-Tray testing method. The State Board of Health requires that bacteriological results must be 'ABSENCE' or less than 1 (for Quanti-Tray method) to meet drinking water requirements. All other testing parameter results must be below **MCL** to meet drinking water requirements. (***MCL-Maximum contaminant level** is the highest concentration of chemicals permitted in drinking water systems*)

Thank you for the opportunity to service the needs of your company.

Sincerely,

Jonathan H. V. Le

Technical Manager



Yosemite Alpine CSD  
P.O.Box 31  
Fish Camp, CA 93623

Project Number: Distribution  
Project Name: CA2210923  
Project Manager: Tim McGinty

Work Order No.:

**ANALYTICAL REPORT FOR SAMPLES**

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
Outside Tap @ (Tim's House)	2501202-01	Water	14-Jan-25 11:00	14-Jan-25 16:20



Yosemite Alpine CSD  
P.O.Box 31  
Fish Camp, CA 93623

Project Number: Distribution  
Project Name: CA2210923  
Project Manager: Tim McGinty

Work Order No.:

**Microbiological Parameters by APHA Standard Methods**

Analyte	Result	Reporting		Dilution	Batch	Analyzed	Method	MCL	Notes
		Limit	Units						

**Outside Tap @ (Tim's House) (2501202-01) Water**    **Sampled: 14-Jan-25 11:00**    **Received: 14-Jan-25 16:20**

Residual Chlorine	ND	0.0200	mg/L	1	AA51417	14-Jan-25	Hach (10ml Vial & Reagent)		
Total Coliforms	< 1.0	1	MPN/100 ml	"	AA51427	14-Jan-25	SM9223B/QT		
E. Coli	< 1.0	1	"	"	AA51427	"	"		



Yosemite Alpine CSD P.O.Box 31 Fish Camp, CA 93623	Project Number: Distribution Project Name: CA2210923 Project Manager: Tim McGinty	Work Order No.:
--	---	-----------------

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	RPD	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-----	-------

**Notes and Definitions**

Item	Definition
------	------------

Dry	Sample results reported on a dry weight basis.
ND	Analyte NOT DETECTED at or below the reporting limit.

<i>mg/L = milligrams per Liter = ppm</i>	<i>G- Grab Sample</i>
<i>ug/L = micrograms per Liter = ppb</i>	<i>C-Composite Sample</i>

*Comp-Grab- Composite of 4 Grab Sample during 24hrs Grab period and composite into 1 sample prior analysis*

*DLR = Detection Limit for Purpose of Reporting.  
 Exceptional sample matrices or interferences may result in higher detection limits.*

**MCL- Maximum contaminant level (MCL) is the highest concentration of chemicals permitted in drinking water systems**

RPD	Relative Percent Difference
%REC	Percent Recovery
Source	Sample that was matrix spiked or duplicated.

MMO-MUG-P/A - Total Coliform and E.Coli Test in Drinking Water by MMO-MUG, using Standard Method 22nd Edition.

The State Board of Health requires that bacteriological results must be 'ABSENCE' or less than 1.1 (for MTF method) to meet drinking water requirements.

