



**PRECISION ENVIRO-TECH**

**Analytical Laboratory**

3935 N. Coronado Ave, Stockton CA. 95204 Phone: (209) 477-8105

11 May 2022

Tim McGinty

Yosemite Alpine CSD

P.O.Box 31

Fish Camp, CA 93623

RE: Distribution\_CA\_2210923

Enclosed are the results for sample(s) received on 10-May-22 18:23 by Precision Enviro-Tech. The sample(s) were analyzed according to instructions in accompanying chain-of-custody, utilizing EPA or other ELAP approved methodologies and . Results are summarized on the following pages.

Thank you for the opportunity to service the needs of your company.

Sincerely,

Jonathan H.V. Le

Laboratory Director



Yosemite Alpine CSD  
P.O.Box 31  
Fish Camp, CA 93623

Project Number: CA2210923  
Project Name: Distribution\_CA\_2210923  
Project Manager: Tim McGinty

Work Order No.:

**ANALYTICAL REPORT FOR SAMPLES**

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
Outside Tap @ 7691 Forest Rd	2051028-01	Water	10-May-22 11:17	10-May-22 18:23



Yosemite Alpine CSD  
P.O.Box 31  
Fish Camp, CA 93623

Project Number: CA2210923  
Project Name: Distribution\_CA\_2210923  
Project Manager: Tim McGinty

Work Order No.:

**Microbiological Parameters by APHA Standard Methods**

Analyte	Result	Reporting			Analyzed	Method	MCL	Notes
		Limit	Units	Dilution				

**Outside Tap @ 7691 Forest Rd (2051028-01) Water    Sampled: 10-May-22 11:17    Received: 10-May-22 18:23**

Residual Chlorine	ND	0.0200	mg/L	1	10-May-22	Hach (Field)		
Total Coliforms	ABSENT	1	A/P/100mL	"	10-May-22	SM 9223 B		
E. Coli	ABSENT	1	"	"	"	"		



Yosemite Alpine CSD P.O.Box 31 Fish Camp, CA 93623	Project Number: CA2210923 Project Name: Distribution_CA_2210923 Project Manager: Tim McGinty	Work Order No.:
--	--	-----------------

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	RPD	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-----	-------

**Notes and Definitions**

Item	Definition
Dry	Sample results reported on a dry weight basis.
ND	Analyte NOT DETECTED at or below the reporting limit.
<i>mg/L = milligrams per Liter = ppm</i>	<i>G- Grab Sample</i>
<i>ug/L = micrograms per Liter = ppb</i>	<i>C-Composite Sample</i>
	<i>Comp-Grab- Composite of 4 Grab Sample during 24hrs Grab period and composite into 1 sample prior analysis</i>
	<i>DLR = Detection Limit for Purpose of Reporting. Exceptional sample matrices or interferences may result in higher detection limits.</i>
	<i>MCL- Maximum contaminant level (MCL) is the highest concentration of chemicals permitted in drinking water systems</i>
RPD	Relative Percent Difference
%REC	Percent Recovery
Source	Sample that was matrix spiked or duplicated.

MMO-MUG-P/A - Total Coliform and E.Coli Test in Drinking Water by MMO-MUG, using Standard Method 22nd Edition.

The State Board of Health requires that bacteriological results must be 'ABSENCE' or less than 1.1 (for MTF method) to meet drinking water requirements.

